

Modification Certificate

Certificate of modification for the fire detection and fire alarm system at: MOORCOT COURT

Address: BIDEFORD DRIVE, WYTHENSHAW, M23 0QW

I being the person(s) responsible (as indicated by my/our signatures below) for the installation of the fire detection and fire alarm system, particulars of which are set out below, CERTIFY that the said modification work for which I have been responsible complies to the best of **My** knowledge and belief with the recommendations of 46.4 of BS 5839-1:2017 except for the variations, if any, stated in this certificate.

Name (in block letters): JACK PARKINSON

Position : FIRE ALARM ENGINEER

Signature:



Date : 06/10/2023

For and on behalf of: FIELDWAY GROUP

Address: 12 PARAPOUNT BUSINESS PARK, HUYTON

Postcode: L36 6AW

The extent of liability of the signatory is limited to the system described below.

Extent of system covered by this certificate:

REMOVE MCPS FROM COMMON AREA USED BY RESIDENTS

Variations from the recommendations of 46.4 of BS 5839-1:2017:

NONE

- Following the modifications, the system has been tested in accordance with the recommendations of 46.4.2 of BS 5839-:2017
- Following the modifications, as fitted drawings and other system records have been updated as appropriate

I the undersigned confirm that the modifications have introduced no additional variations from the recommendations of BS 5839-:2017, other than those recorded above

Signed :



Capacity : FIRE ALARM ENGINEER

Date: 06/10/2023

(e.g. maintenance organisation, system designer, consultant or user representative)